

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Action Taken		
HERKIMER 1	1/12/2024 05:54	1/18/2024 13:22	70284330001	Lead	<1.0	5	ug/L			
HERKIMER 2	1/12/2024 05:55	1/18/2024 13:26	70284330002	Lead	5.1	5	ug/L	Room 110	Drinking Fountain	Posted Sign
HERKIMER 3	1/12/2024 06:04	1/18/2024 13:30	70284330003	Lead	2.6	5	ug/L			
HERKIMER 4	1/12/2024 06:05	1/18/2024 13:31	70284330004	Lead	1.1	5	ug/L			
HERKIMER 6	1/12/2024 06:06	1/18/2024 13:34	70284330005	Lead	1.1	5	ug/L			
HERKIMER 7	1/12/2024 06:07	1/18/2024 13:39	70284330006	Lead	<1.0	5	ug/L			
HERKIMER 15	1/12/2024 06:10	1/18/2024 13:48	70284330007	Lead	10.2	5	ug/L	Room 1246	Library Office	Posted Sign
HERKIMER 22	1/12/2024 05:57	1/18/2024 13:52	70284330008	Lead	<1.0	5	ug/L			
HERKIMER 23	1/12/2024 06:25	1/18/2024 13:59	70284330009	Lead	<1.0	5	ug/L			
HERKIMER 34	1/12/2024 05:59	1/18/2024 14:30	70284330010	Lead	1.1	5	ug/L			
HERKIMER 35	1/12/2024 06:00	1/18/2024 14:37	70284330011	Lead	5.2	5	ug/L	Room 118	Drinking Fountain	taken out of service
HERKIMER 37	1/12/2024 06:01	1/18/2024 14:42	70284330012	Lead	<1.0	5	ug/L			
HERKIMER 38	1/12/2024 06:02	1/18/2024 14:43	70284330013	Lead	5.3	5	ug/L	Room 120	Drinking Fountain	taken out of service
HERKIMER 40	1/12/2024 06:34	1/18/2024 14:45	70284330014	Lead	<1.0	5	ug/L			
HERKIMER 42	1/12/2024 06:38	1/18/2024 14:46	70284330015	Lead	2.0	5	ug/L			
HERKIMER 44	1/12/2024 06:42	1/18/2024 14:48	70284330016	Lead	<1.0	5	ug/L			
HERKIMER 46	1/12/2024 06:39	1/18/2024 14:53	70284330017	Lead	<1.0	5	ug/L			
HERKIMER 48	1/12/2024 06:43	1/18/2024 14:54	70284330018	Lead	<1.0	5	ug/L			
HERKIMER 50	1/12/2024 06:40	1/18/2024 14:56	70284330019	Lead	<1.0	5	ug/L			
HERKIMER 52	1/12/2024 06:33	1/18/2024 14:57	70284330020	Lead	<1.0	5	ug/L			
HERKIMER 55	1/12/2024 06:17	1/18/2024 14:59	70284330021	Lead	1.5	5	ug/L			
HERKIMER 58	1/12/2024 06:30	1/18/2024 15:00	70284330022	Lead	<1.0	5	ug/L			
HERKIMER 59	1/12/2024 06:31	1/18/2024 15:02	70284330023	Lead	1.3	5	ug/L			
HERKIMER 60	1/12/2024 06:32	1/18/2024 15:04	70284330024	Lead	2.3	5	ug/L			
HERKIMER 62	1/12/2024 06:37	1/18/2024 15:05	70284330025	Lead	<1.0	5	ug/L			
HERKIMER 64	1/12/2024 05:52	1/18/2024 15:07	70284330026	Lead	<1.0	5	ug/L			
HERKIMER 69 DF ACROSS LIBRARY	1/12/2024 06:16	1/18/2024 15:11	70284330027	Lead	<1.0	5	ug/L			
HERKIMER 72 DF ACROSS RM 151	1/12/2024 06:20	1/18/2024 15:13	70284330028	Lead	<1.0	5	ug/L			

NYSDOH Action Level for Lead In Schools of 5 ppb